10. WIND MICROCLIMATE

Introduction

- 10.1 This Wind Microclimate chapter has been prepared by SRE Ltd to assess the likely significant effects of the Development on the environment in respect of Wind Microclimate. The chapter has been updated in relation to the transposed wind rose data and in direct response to a number of points of clarification raised in the Temple Group Ltd ES Interim and Final Review Reports (FRR 001 dated 14/04/2021 & FRR 002 dated 05/05/2021).
- 10.2 This chapter describes the relevant policy context, the methods used to assess the potential impacts, and the likely significant effects during demolition, construction and once the Development is complete and operational. Where applicable, mitigation measures are identified to prevent, reduce or offset the effects and the nature and significance of the residual effects is assessed.
- 10.3 This chapter draws on the technical assessment findings in <u>a revised</u> 'SRE Microclimate Report' which is included within Appendix 10.1. Through undertaking a Computational Fluid Dynamic (CFD) wind study for the Site, a robust study of the microclimate conditions generated by the Development has been provided.

Legislation, Policy and Guidance Context

10.4 The wind microclimate assessment has been undertaken within the context of relevant legislation, planning policies and guidance documents. These are summarised below:

National Planning Policy

National Planning Policy Framework

10.5 In February 2019, the Government published an updated version of the National Planning Policy Framework (NPPF). There are no policies or statements that are directly related to the wind microclimate. However, the benefits of a high-quality built environment are emphasised in the NPPF. For example:

"Planning policies and decisions should ensure that developments: [...] a) will function well and add to the overall quality of the area, not just for the short term but over the lifetime of the development; [...] f) create places that are safe, inclusive and accessible and which

promote health and well-being, with a high standard of amenity for existing and future users..."

National planning Practice Guidance

10.6 The National Planning Practice Guidance (NPPG) was updated in 2019 and there is no guidance related to tall buildings and wind microclimate issues.

UK Climate Projections (UKCP18) (2019)

- 10.7 The Met office's UK Climate Projections (UKCP18) presents a number of different predicted climate scenarios. The 'Climate Projects Report' published by UKCP18 presents the probable changes in wind speed for 2070 2099 in both the summer and winter seasons.
- 10.8 Based on these predictions, the current trends in the climate change are not likely to have any significant effects on the predicted wind microclimate conditions in and around the Development. It is therefore not necessary to provide any quantitative analysis of the increase in storm frequency and its associated implication on the effect on the wind microclimate for the Development.

Regional Planning Policy

10.9 The London Plan places great importance on the creation and maintenance of a high-quality environment for London. The following policies apply in relation to wind microclimate:

Policy 7.6 Architecture

"Architecture should make a positive contribution to a coherent public realm, streetscape and wider cityscape. It should incorporate the highest quality materials and design appropriate to its context."

"Buildings and structures should: [...] d) Not cause unacceptable harm to the amenity of surrounding land and buildings, particularly residential buildings, in relation to privacy, overshadowing, wind and microclimate. This is particularly important for tall buildings."

Policy 7.7 Location and Design of Tall and Large Buildings

"Tall and large buildings should be part of a plan led approach to changing or developing an area by the identification of appropriate, sensitive and inappropriate locations. Tall and large buildings should not have an unacceptably harmful impact on their surroundings.

Applications for tall or large buildings should include an urban design

analysis that demonstrates the proposal is part of a strategy that will meet the criteria below. This is particularly important if the site is not identified as a location for tall or large buildings in the borough's LDF [Local Development Framework].

Tall buildings: a) Should not affect their surroundings adversely in terms of microclimate, wind turbulence, overshadowing, noise, reflected glare, aviation and telecommunication interference."

The London Plan Intend to Publish - Spatial Development Strategy for Greater London (202119)^{iv}

10.10 The 'new' London Plan <u>places great importance on the creation and maintenance of a high-quality environment for London. The following policies apply in relation to wind microclimaterefines the above policies that apply in relation to wind microclimate:</u>

Policy D8 Public Realm:

"Development Plans and development proposals should: [...] G ensure buildings are of a design that activates and defines the public realm, and provides natural surveillance. Consideration should also be given to the local microclimate created by buildings, and the impact of service entrances and facades on the public realm."

Policy D9 Tall Buildings

"C Development proposals should address the following impacts: [...] 3) environmental impact a) wind, daylight, sunlight penetration and temperature conditions around the building(s) and neighbourhood must be carefully considered and not compromise comfort and the enjoyment of open spaces, including water spaces, around the building.

[...] 4) cumulative impacts a) the cumulative visual, functional and environmental impacts of proposed, consented and planned tall buildings in an area must be considered when assessing tall building proposals and when developing plans for an area. Mitigation measures should be identified and designed into the building as integral features from the outset to avoid retro-fitting."

Sustainable Design and Construction – Supplementary Planning Guidance (2014)

10.1 The GLA has previously provided additional planning guidance around Micro-Climate and large buildings (as per The London Plan Policy 7.6: Architecture), and recommended the methodology for assessing local wind speed in Para 2.3.6 – which is being undertaken for the Development:

"Large buildings have the ability to alter their local environment and affect the micro-climate. For example, [...] they can influence how wind travels across a site, potentially making it unpleasant at ground level or limiting the potential to naturally ventilate buildings. One way to assess the impact of a large building on the comfort of the street environment is the Lawson Comfort Criteria. [...]

Where a proposed development is significantly taller that it's surrounding environment, developers should carry out an assessment of its potential impact on the conditions at ground level, and ensure the resulting design of the development provides suitable conditions for the intended uses."

Local Planning Policy

Royal Borough of Kingston upon Thames – Core Strategy (2012)vi

- 10.2 Although the Royal Borough of Kingston upon Thames (RBKuT) Local Development Framework: Core Strategy (2012) does not reference wind microclimate directly, it does consider in Policy CS8 that tall buildings 'may be appropriate in the Borough's town centres' and refers any assessment back to the London Plan policies.
- 10.3 However, the principles of good design are stated throughout the Core Strategy, including:

Policy DM10 Design Requirements for New Developments (including House Extensions):

"Development proposals will be required to incorporate principles of good design. The most essential elements identified as contributing to the character and local distinctiveness of a street or area which should be respected, maintained or enhanced [...] Development proposals should also:

K. have regard to the amenities of occupants and neighbours, including in terms of privacy, outlook, sunlight/daylight, avoidance of visual intrusion and noise and disturbance,

q. have regard to the public realm and to ways in which it can be enhanced as an integral part of the design of the development."

Guidance Documents

Guidance on tall buildings (2007)vii

10.11 English Heritage and the Commission for Architecture and the Built Environment (CABE) produced a revised and updated version of their joint guidance on tall buildings. The final version was released in July 2007 and in the section Criteria for evaluation, it states that:

"[...] planning permission for tall buildings should ensure therefore

that the following criteria are fully addressed: [...] The effect on the local environment, including microclimate".

Historic England Advice Note 4: Tall Buildings (2015)viii

10.12 The Historic England Advice Note 4: Tall Buildings states in Section 4.7:

"Planning applications for tall buildings are likely to require an environmental impact assessment (EIA), which would be expected to address matters in respect of both the proposed building and its cumulative impact, including: [...] e. Other relevant environmental issues,"

Assessment Methodology

- 10.13 The following section outlines the methodologies applied to identify and assess the likely significant wind effects resulting from the Development.
- 10.14 The aims of the wind microclimate assessment are as follows:
 - To assess the suitability of the wind microclimate at residential amenity spaces within the Development, for outdoor seating in the summer;
 - To assess the wind conditions at ground level amenity spaces across the Development and also the off-site adjacent residential spaces in the summer;
 - To assess the suitability of entrances of the Development to achieve suitable conditions throughout the year; and
 - To assess the wind microclimate along the pedestrian thoroughfares within the Site and adjacent areas throughout the year.

Consultation

- 10.15 The proposed approach to assessment of the effects in relation to Wind Microclimate was set out in the submitted EIA Scoping Report (April 2020) (Appendix 2.1 of the ES). The Scoping Opinion received from RBKuT (June 2020) (Appendix 2.2 of the ES) agreed with the proposed approach to assessment.
- 10.16 No further consultation has been undertaken specifically with regard to Wind Microclimate.

Baseline Characterisation

10.17 The baseline conditions at the Site are characterised by:

- Review of available meteorological data to establish the prevailing wind directions and (if applicable) any adjustment of that data for the Site-specific application in the modelling;
- Establishing a 3D model of the existing buildings in, and surrounding, the Site within a >400m radius and subsequent transient CFD simulation of the existing Site conditions. This radius is sufficient to capture the localised, building-specific wind effects on the local wind microclimate. Buildings and terrain located further away from the Site are modelled in form and mass in order to modify the behaviour of the wind to reflect the real conditions on-site;
- Overall measurement and results have been shown within the modelled area covering the
 4 aims of the microclimate assessment (listed above); and
- The analysis of the Existing Condition scenario was undertaken using the same modelling and analysis methods used for the Development scenarios (as detailed later in the chapter).

Impact Assessment Methodology

Construction Phase

- 10.18 The potential microclimate impacts and likely significant effects during construction (including demolition) have not been directly assessed within the transient CFD modelling. This is because construction is a temporary condition and would be highly variable as the Development is built out in phases with specific existing buildings being demolished, and new buildings being constructed.
- 10.19 Construction activity is likely to be less sensitive to general wind conditions due the nature of the Site during construction (ie site hoardings, restricted site access for workers) compared to when the Development is completed (ie new pedestrian throughfares, new entrances and open space). Therefore, a qualitive assessment has been provided based on professional judgement informed by the background wind microclimate in the area and the results of the assessed scenarios for the baseline condition and completed Development.

Completed Development Phase

10.20 To predict the local wind environment associated with the completed Development, and the resulting pedestrian comfort within and immediately surrounding the Site, transient CFD modelling has been undertaken covering 16 no. wind directions.

- 10.21 The latest transient CFD modelling is a highly accurate and effective way of assessing the pedestrian level wind microclimate at and surrounding a site allowing it to be quantified and classified in accordance with the widely accepted Lawson Comfort Criteria (LCC), a summary of which is provided later in this chapter.
- 10.22 CFD modelling provides a detailed assessment of the mean and gust wind conditions around the Site and the Development for the tested wind directions, in terms of pedestrian comfort and pedestrian safety, and provides a basis to assess the potential wind microclimate impacts and likely effects of the Development with regards to its intended use. Strong winds are also reported when they occur.

Assumptions and Limitations

- 10.23 It is assumed that there will be restricted access to the majority of the Site during demolition and construction works, and therefore windier conditions will be tolerable in these areas which will not typically be for pedestrian use where the tolerable wind speed threshold would be lower.
- 10.24 It is assumed that on-site construction workers will be following all relevant health and safety protocols, and that any wind-sensitive operation would cease during high wind / storm events.
- 10.25 This assessment is based on the <u>annual wind conditions and also includes Windiest (worst-case)</u> wind conditions expected to be encountered during the winter season (December, January and February) in the UK. In addition, the summer wind conditions are considered due to the presence of outdoor amenity spaces at street, podium and balcony levels (Phase 1 only) across the Site.
- 10.26 This study complies with the standard methodology set out by the LCC for wind microclimate assessments.

CFD Modelling Methodology

- 10.27 In order to assess wind conditions against the full LCC, the CFD study should determine mean and gust wind speeds for a minimum of 16 no. wind directions. It is also an essential requirement of a CFD study that it can calculate peak wind speeds with a low probability of occurrence to determine the likelihood of distress or safety thresholds being exceeded.
- <u>10.28</u> The computational process involves the calculation of the equations of fluid motion. In this study a transient Computational Fluid Dynamic (CFD), based on the Lattice Boltzmann method

- (LBM), has been used. Strong winds are calculated from the gust equivalent mean which are derived from equations based on the total standard deviation.
- 10.2810.29 A computational 'mesh' was created to represent the geometry by dividing the domain into a large number of cell volumes. During the simulation, the values of each variable are determined in each cell of the mesh and a comprehensive assessment of velocity and scalar variation within the calculation domain was obtained.
- 10.2910.30 When assessing pedestrian level wind speed, the appropriate terrain roughness and wind velocity profile must be considered. The surface roughness applied to the CFD model<u>in</u> the upstream profile (atmospheric wind boundary profile) is 0.30 which corresponds to the Atmospheric Boundary Layer (ABL) profile for a suburban area.
- 10.3010.31 The CFD modelling has assessed the maximum parameter 3D massing for Phases 2-5 (Outline element of the Development) and the detailed 3D architectural model for Phase 1 (Detailed element of the Development).
- 10.31 The assessment quantifies the expected wind microclimate in pedestrian area at ground level and terrace level of the Development, and for the detailed Phase 1 element of the Development only, individual balconies & terraces. The modelled wind speed data is benchmarked against the LCC to determine the suitability of the Site for different pedestrian activities. Strong winds are considered and results for the windiest season are presented, as well as results for the summer when amenity spaces are more likely to be used frequently.
- 10.3210.33 Analysis was also undertaken to assess compliance with the LCC and Lawson Distress Criteria (LDC) Lawson 'safe criteria' by interpolating the transient CFD results of the site with hourly weather data in order to predict the frequencies of wind speeds across the course of a whole year.
- 10.3310.34 Wherever possible and appropriate, the windiest (winter) season has been used to assess the likely wind conditions for the various scenarios.

Assessment Scenarios

- 10.3410.35 The following three scenarios have been modelled:
 - Scenario 1: Existing Site with existing surrounding buildings;
 - Scenario 2: Development with existing surrounding buildings; and

- Scenario_-3:_-Development (including mitigation measures) with existing surrounding buildings.
- 10.3510.36 There are no committed developments immediately adjacent to the Site to be taken into account within a further cumulative scenario. The only proposed new residential scheme is located over 100m away at the southern end of Hampden Road which is located south east of the Site. This committed development is not relevant as this wind direction is the weakest and least frequent wind condition for the area.

Pedestrian Wind Comfort Criteria

- 10.3610.37 The assessment uses the Lawson Comfort Criteria (LCC) which sets five threshold wind speeds and then dictates the probability of wind speeds exceeding that threshold. The different threshold values, as well as the probability values, determine the likely reaction of an average pedestrian to the wind.
- 10.37 10.38 Each wind level corresponds to a pedestrian activity that could be achieved in an acceptable manner (sitting, standing etc) and the probability is calculated using the statistic weather data for the local area. If the measured wind conditions exceed the threshold wind speed for more than 5% of the time, then they are unacceptable for the stated pedestrian activity and the expectation is that people will not use the particular area for its intended purpose.
- 10.3810.39 The LCC sets out five levels of pedestrian activities in ascending order relating to wind conditions: frequent sitting, occasional sitting, standing and walking. The fifth level is for those conditions that are uncomfortable for all pedestrian uses. This is summarised in the following table.

Table 13.1: Lawson Comfort Criteria Thresholds

Colour	Comfort Category	Wind Speed	Probability	Description
	Outdoor Dining	2	<5	Reading a newspaper and eating and drinking, sitting in outdoor cafes, patios, terraces, benches, gardens, parks (considered to be of long duration)Light breeze suitable for outside restaurants and seating areas where one can read a paper or comfortably sit for long periods of time
	Pedestrian Sitting	4	<u><</u> >5	Pedestrian Sitting, sitting in parks and outdoor spacesBreeze suitable for shorter periods of sitting in parks and outdoor spaces

	Pedestrian Standing	6	<u><</u> >5	Pedestrian Standing (or sitting for a short time or exposure). Appropriate for bus stops, building entrances or exits, children's play areas Gentle breeze suitable for entrances, play areas and bus stops
_	Pedestrian Walking	8	<u><</u> >5	General areas of walking, strolling and sightseeing, window shopping, public/private sidewalks, pathways, public spaces Moderate breeze suitable for slow paced walking with occasional stops, strolling and sightseeing, window shopping, public/private sidewalks, pathways, public spaces
	Business Walking/Cycling	10	<u><</u> >5	Local areas around tall buildings where people are not expected to linger. Walking from one place to another quickly, or where individuals pass rapidly through local areas around buildings, roads and car parks, cyclists' pathwaysWindy conditions that are uncomfortable for all pedestrian activities
	Uncomfortable	>10	>5	Uncomfortable for all pedestrian activities

- 10.3910.40 The LCC are derived for open air conditions and assume that pedestrians would be suitably dressed for the season. Thermal comfort is not evaluated as part of this microclimate assessment.
- 10.4010.41 The LDC specifies two strong wind categories as part of the assessment of 'Safe Criteria', and exceeding these indicate a need for remedial measures or a careful assessment of the expected use of that location. The LDC uses a slightly different scaling than the LCC Pedestrian Wind Comfort in order to reflect these categories.
- 10.4110.42 The location is 'safe' if these infrequent strong winds appear for less than 0.023% (e.g. 2 hrs) of the whole year period. Outside of these parameters the location is deemed 'unsafe'. The lower limit, 15m/s, is intended to identify wind conditions which elderly people, cyclists or children may find physically difficult. Infrequent strong wind can cause some pedestrians to have difficulties with walking, to stumble or fall. Wind speeds that exceed the upper limit, 20m/s, represent a safety risk for all members of the population. This is summarised in the following Table:

Table 13.2: Lawson Safe Criteria

Colour	Comfort Category	Wind Speed	Probability	Description
	SittingSafe 4 ←5			Reading a newspaper and eating and drinking, sitting in outdoor cafes, patios, terraces, benches, gardens, parks_

Standing	6	<5	Appropriate for bus stops, building entrances or exits, children's play areas Gentle breeze suitable for entrances, play areas and bus stops				
 Strolling	8	<5					
Business Walking/ Cycling	10	<5	Moderate breeze suitable for slow paced walking with occasional stops, strolling and sightseeing, window shopping, public/private sidewalks, pathways, public spaces				
Uncomfortable	>10	>5	Windy conditions that are uncomfortable for all pedestrian activities				
Unsafe Frail	>15	>0.023	Safety risk for elderly people, cyclists or children, difficulties with walking, to stumble or fall				
Unsafe All	>20	>0.023	Safety risk for all members of the population				

Defining Significance

- 10.42 10.43 The wind conditions are compared with the intended pedestrian use. With regards the Development, the following locations will be assessed with the required wind conditions specified for each use:
 - Thoroughfares & Roads targeting walking wind conditions;
 - Entrances targeting standing wind conditions; and
 - Amenity Areas: ground floor, podium and balconies are targeting a mix of sitting and standing conditions during the summer season.

Scale & Significance

10.43 10.44 The criteria used in the assessment of effects is based upon the relationship between the desired pedestrian use of an area of the Development and its immediate surroundings (based on the LCC comfort categories) and, the predicted wind conditions at that area. This approach allows for the microclimate assessment to account for any change in pedestrian activity that might arise because of the Development.

10.4410.45 The scale used within the assessment to assess the significance of an effect is:

- Negligible (no effect) wind conditions are those required;
- Minor Adverse wind conditions are one category windier than required;
- Moderate adverse wind conditions are two categories windier than required; and
- Major Adverse wind conditions are three categories windier than required.
- 10.4510.46 The minor, moderate and major categories indicate the degree of the difference between the desired microclimate and the predicted (assessed) microclimate.

- 10.4610.47 Any adverse effect is a 'significant effect' because it implies that a location, or area, has a wind microclimate that is unsuitable for the desired use of that area. On this basis, effects that are adverse need mitigating. Similarly, negligible effects are not considered significant as they do not require wind mitigation measures.
- 10.47 10.48 Effects during the construction works are temporary: direct, local and short-term.
- 10.48 10.49 Effects once the Development is completed are permanent: direct, local and long-term.
- <u>10.4910.50</u> Strong winds (affecting pedestrian safety) are not assigned a scale of effect and an overall significance but are reported separately. Any strong wind exceedance is significant and mitigation is required (as per adverse effects related to pedestrian comfort).

Baseline Condition - Scenario 1

- The UK Meteorological Office supplies records of the number of hours that wind occurs for ranges of wind speed (using the Beaufort Scale) and by direction. Meteorological data for London Heathrow Airport over a 15 year period (2006-2020)s, shown in the wind rose in SRE Microclimate Analysis Report (Appendix 10.1) and has been transposed to the Site by applying a roughness factor with information about the topography derived through BREVe software before being used in this assessment—as this is deemed to provide an accurate representation of the local wind microclimate for the Kingston on Thames area.
- 10.5010.52 The meteorological data obtained for London indicates that the prevailing winds throughout the year are from the South-West through to the West (i.e. 225 to 2705 degrees on the compass). This is typical for many areas of Greater London and southern England. There is a secondary peak of weaker winds from the North-East (ie 75 degrees on the compass) during the late spring and early summer.
- 10.5110.53 CFD modelling results for pedestrian wind comfort for the existing site and the adjacent areas are shown in Figure 10.1, 10.2 -& 10.32 for the annual, windiest (winter) and summer seasons. The safety exceedances due to strong winds for both seasons annually are presented in Figures 10.4.3 & 10.4.

Pedestrian Comfort

10.5210.54 Annually, During the windiest (winter) season, wind conditions are suitable for sitting to <u>business</u> walking use throughout the Site and the surrounding area.

- 10.55 During the windiest (winter) season, wind conditions are suitable for sitting to business walking use throughout the Site and the surrounding area, including four localised uncomfortable wind conditions and further eight business walking conditions within the site.
- 10.5310.56 During the summer season, the wind conditions are suitable for sitting to walking use, with five localised areas of Business Walking identified throughout the Site and the surrounding area.

Thoroughfares

- 10.57 Annually the wind conditions are suitable for sitting to business walking use throughout the Site and the surrounding area, one level above suitable for the use. Localised areas of business walking wind speeds are present at the northern section of Hampden Road, the pedestrian access to the East of Tower Block C and in the vicinity of the entrance to the podium to the East of Tower Block A.
- 10.5410.58 During the windiest (winter) season and the summer, wind conditions are suitable for sitting to uncomfortable wind conditions walking use throughout the Site and the surrounding area, two levels above suitable for the use. –Four instances of uncomfortable wind levels are noted, three around the thoroughfare and access road to Tower Block D (NW, NE and SE corners) and the pedestrian access to the East of Tower Block C which crosses part of Cambridge Road.

During the summer season, the wind conditions are suitable for sitting to walking use throughout the Site and the surrounding area.

Entrances

10.5510.59 During the windiest (winter) season, wind conditions are suitable for sitting to standing for all existing on-site and off-site entrance locations, which are acceptable conditions for the intended use. Higher wind speeds are noted in the vicinity of the entrance to Blocks A & D.

Pedestrian Crossings

10.5610.60 During the windiest (winter) season, wind conditions are suitable for sitting to walking use throughout most of the Site and the surrounding area. There is one instance of business walking at the pedestrian crossing NE of Tower Block D, at the junction with Hamden Road, one level above suitable for the use.

Ground Level Amenity - Sitting

- 10.61 Annually the wind conditions are suitable for sitting and standing for the main existing ground level amenity space around the Site. However there are two main instances concerning the amenity space west of Block A which has areas of pedestrian standing one level above the suitable use, along with the small semi-private communal garden and play area adjacent to Tower Block D (SW of Burritt Rd & Hampden Rd Junction) which has wind conditions suitable for business walking, two levels windier than suitable for a sitting location.
- 10.5710.62 During the summer season, wind conditions are suitable for sitting for almost all existing ground level amenity space around the Site other than . Tthe small semi-private communal garden and play area adjacent to Tower Block D (SW of Burritt Rd & Hampden Rd Junction) which has wind conditions suitable for pedestrian business walking, one two levels windier than suitable for a sitting location.

Podium Level Amenity - Seating

10.5810.63 During the summer season, Annual and summer wind conditions are one level windier than suitable for a sitting location on the two main podium areas adjacent to Tower Blocks A & B. It should also be noted that the ground level area leading up to the access point for, and directly adjacent to, the Tower Block A podium has acceptable wind conditions for that area suitable for walking use.

Roads

10.5910.64 During the windiest (winter) season, wind conditions are mostly suitable for sitting to walking use throughout the Site and the surrounding area. There are two occurrences of business walking on Hampden Road and East of Tower Block C on Cambridge Road, one level above the intended use, and a localised area of uncomfortable wind on the edge of Cambridge Road again to the East of Tower Block C, two levels above suitable for the use.

Strong Winds

- 10.6010.65 During the windiest (winter) seasonAnnually, wind conditions are predominantly suitable for sitting to walking use throughout the Site and the surrounding area.
- 10.6110.66 There are seven ten occurrences at ground level (all around existing Tower Blocks A, A, B, C & D and building E) of strong winds exceeding 15m/s for more than the safety threshold of >0.023% of time annually (e.g. 2hrs) in the baseline scenario. This equates to

'unsafe frail' wind conditions, which is two wind conditions above suitable for the use.

- 10.6210.67 The wind conditions around the rest of the existing Site are suitable for sitting to strolling use-during the windiest season and sitting to standing use during the summer season, with all remaining locations having acceptable wind conditions for the current use.
- <u>10.63</u>10.68 There are no safety exceedances <u>above 20m/s equating to 'unsafe all'</u> due to strong winds in the <u>annual</u> baseline condition.

Likely Significant Effects

Development condition - Scenario 2

- 10.6410.69 The following effects have been assessed for the Development for the construction and operational phases.
- 10.6510.70 CFD modelling results for pedestrian wind comfort for the Development and the adjacent areas are shown in Figures 10.5, 10.6 & 10.76 for the annual, windiest (winter) and summer season. The safety exceedances due to strong winds for both seasons annually are presented in Figures 10.87 & 10.8.

Construction Phase

- 10.6610.71 Wind conditions during the construction phase (including demolition) would be expected to adjust during the phased construction work from the Baseline Condition (Scenario 1) to the likely wind conditions assessed for the Development once constructed (Scenarios 2 & 3).
- 10.6710.72 The wind conditions in the Baseline Condition range from suitable for sitting to walking use during the windiest season. The construction of the Development would result in conditions for pedestrian wind comfort ranging from suitable for sitting to walking use during the windiest season, but with six5 locations with instances of strong winds exceeding the safety threshold by being assessed as 'Unsafe Frail' throughout the Site. Therefore, some mitigation measures would need to be implemented prior to the completion and occupation of the Development.
- 10.6810.73 Hoarding or other sheltering measures would be implemented around the construction areas to shelter pedestrian routes during the demolition and construction works of the Development. Wind conditions on-site during the construction phases of the Development

would therefore represent a **negligible effect** (not significant) and is therefore suitable for construction workers.

10.6910.74 As noted above, for the parts of the Site that will remain in use throughout the phased construction works, existing and new buildings' access and entrance points will be entirely separate to the construction works and protected via secure hoardings and covered access routes (as necessary) from the construction works and also the wind conditions. There will be no significant wind effects to existing users throughout the construction phase.

Operational Phase

Pedestrian Comfort

- 10.7010.75 With the completion of the Development, the results of the wind microclimate assessment indicate annual wind conditions ranging from suitable for sitting to pedestrian walking use. during the windiest season. However, 5 no. locations with instances of strong winds assessed as 'Unsafe Frail' have been identified throughout the Site as a direct result of the Development's layout and massing. Therefore, mitigation measures would need to be implemented prior to the completion and occupation of those buildings of the Development.
- 10.76 The wind conditions around the Site and adjacent areas are suitable for activities from sitting to pedestrian walking during both the windiest season and the summer season. However, five incidences of business walking have been identified throughout the Site as a direct result of the Development's layout and massing, one level above suitable for the use. Therefore, mitigation measures would need to be implemented prior to the completion and occupation of those buildings of the Development.
- 10.71 The wind conditions around the Site and adjacent areas are suitable for activities from sitting to pedestrian walking during the summer season.

Thoroughfares

- 10.78 There are four instances of business walking wind conditions on-site thoroughfares, one level above suitable for the use, during the windiest season. Two instances are located to the South of Building D6, one South of Building J4 and one between Buildings M1 and M2 (outline Phase 4). The wind conditions on these thoroughfares would represent **minor adverse effects** (significant) and mitigation is required in these locations.
- 10.79 All the on-site and off-site thoroughfares would have acceptable annual and summer season

wind conditions ranging from suitable for sitting to walking use—during both the windiest season and the summer season, acceptable conditions for the intended use. The wind conditions on these thoroughfares would represent negligible effects (not significant).

Entrances

- 10.7210.80 In close proximity of one two of the access points and entrances within the Development south of Building D6 (outline Phase 2) and west of Building M2 (outline Phase 4) would have annual wind conditions suitable for walking during the windiest season and the summer season, which is one category above the suitable for entrances. This represent a minor adverse effect (significant) and mitigation is required at this these locations.
- <u>10.81</u> All other on-site entrances within the Development would have <u>annual</u>—wind conditions suitable for sitting to standing use during both the windiest season and the summer season, acceptable conditions for entrance locations, which would represent negligible effects (not significant).
- <u>10.7310.82</u> All off-site entrance locations would have wind conditions suitable for sitting and standing use during both the windiest season and the summer season, acceptable wind conditions for entrances, representing **negligible effects** (not significant).

Pedestrian Crossings

All off site pedestrian crossings would have wind conditions suitable for sitting and standing use during both the windiest season and the summer season, acceptable wind conditions for the intended use and representing **negligible effects** (not significant).

- 10.7410.83 There is one instance at an off-site pedestrian crossing of pedestrian walking wind conditions, one level above suitable for the use, both annually and in the windiest season.

 The crossing is located to the NW of Building C1 (detailed Phase 1) representing minor adverse effects (significant) and mitigation is required in this location.
- 10.84 One on-site pedestrian crossing would have annual and windiest season wind conditions suitable for sitting to pedestrian walking, one level above suitable for the use. This is located to the south of Building J4 (outline Phase 3) representing **minor adverse effects** (significant) and mitigation is required in these locations.
- 10.85 All remaining off-site pedestrian crossings would have annual wind conditions suitable for sitting and standing use, acceptable wind conditions for the intended use and representing

negligible effects (not significant).

Ground Level Amenity - Seating

- 10.7510.86 One of Three areas of the ground level amenity spaces within the Development west of Building C3 (detailed Phase 1), east of Building F1 & F2 (outline Phase 3) and south of Building K3 (outline Phase 4), would experience wind conditions suitable for standing during the annual and summer season, which is one category above the suitable for amenity. This represent a minor adverse effect (significant) and mitigation is required at this location.
- <u>10.7610.87</u> All other on-site and off-site ground level amenity seating areas would have wind conditions suitable for sitting use during the <u>annual and</u> summer season, acceptable wind conditions for the intended use and representing **negligible effects** (not significant).

Podium Level Amenity - Seating

- 10.88 At the centre and west of the on-site podium level amenities areas at Block E (detailed Phase 1), this would have wind conditions suitable for from seating to standing with localised areas of pedestrian walking during the annual and summer season, which is one two categoriesy above the suitable for amenity. This represents a minor adversemoderate adverse effect (significant) and mitigation is required at this location.
- 10.7710.89 Additionally the podium between Buildings C1 and C2 would have annual wind conditions from sitting to standing with localised areas on the southern boundary for pedestrian walking. As the podium will provide a mix of amenity seating and access, the wind conditions are two categories above the suitable for amenity. This represents a moderate adverse effect (significant) and mitigation is required at this location.
- 10.7810.90 All other <u>detailed application</u> on-site podium level amenity seating areas would have wind conditions suitable for sitting use during the summer season, acceptable wind conditions for the intended use and representing **negligible effects** (not significant).

Balconies

- 10.7910.91 All balconies have been modelled without any enclosure and as such the results would represent the 'worst case' scenario.
- <u>10.92 Thirty six Twenty-three</u> balconies located on buildings on Blocks B, C & E (detailed Phase 1) would have <u>localised</u> wind conditions suitable for <u>business</u> walking use during the summer

season, which is one-two categoriesy above that suitable for amenity. Of these, fifteen are 'spots' in the corner of the balconies. This represents a minor moderate adverse effect (significant) and mitigation is required at these locations.

- 10.8010.93 There are an additional twelve balconies on buildings on Blocks B, C & E (detailed Phase 1) that also have localised wind conditions suitable for pedestrian walking use during the summer season, which is one category above that suitable for amenity. Most of them are also 'spots' in the corner or on the edges of the balconies. This represents a **minor adverse effect** (significant) and mitigation is required at these locations.
- 10.8110.94 All other balconies would have wind conditions suitable for long term sitting to standing during the summer season, acceptable wind conditions for the intended use, resulting in **negligible effects** (not significant).

Terraces

- One roof terrace on Building E3 (detailed Phase 1) has wind conditions from sitting to business walking during the summer season, two categories above that suitable for amenity space. This represents a moderate adverse effect (significant) and mitigation is required at these locations.
- 10.8210.96 All the other roof terraces would have a mixture of sitting and standing conditions during the summer season. This would be acceptable on the basis that no fixed seating is placed in areas suitable for standing use, otherwise mitigation measures would be required.
- 10.8310.97 The south east corner of the non-accessible roof terrace level located between Buildings C1 and C3 and one between E2 and E3 (detailed Phase 1) would have localised wind conditions suitable for walking use. As these space space are not accessible to building users, no mitigation would be required.

Roads

10.8410.98 Road locations around the Site would have wind conditions ranging from suitable for sitting use to <u>pedestrian</u> walking use during throughout the year (annual) and during -both the windiest season and the summer season, representing **negligible effects** (not significant).

Strong Winds

- 10.8510.99 At ground level, there would be no-six localised areas of expected strong annual winds exceeding the lower upper-safety threshold level 'unsafe frail' of 15m/s for more than 0.023% throughout the year (ie 2 hours). These are located to the South of Blocks D, F, West of Block Q and North & South of Block M. All of these locations require mitigation to eliminate these safety exceedances.
- 10.100 There are no strong annual winds exceeding the upper safety threshold level 'unsafe all' of 20m/s for more than 0.023% throughout the year (ie 2 hours).
- 10.8610.101 However, there are five locations: NW Corners of Buildings C1 & C3 (detailed Phase 1); NW and NE Corners of Building P2 (outline Phase 2); SW Corner of Building K1 (outline Phase 3) and NW Corner of Building M1 (outline Phase 4) that would have instances of strong winds exceeding 15m/s for more than the safety threshold of 0.023% of time annually (e.g. 2hrs) 'Unsafe Frail'. All these locations require mitigation to eliminate these safety exceedances.
- <u>10.8710.102</u> Only <u>one two roof areas on Block C and Block E</u> (detailed Phase 1) will have <u>annual</u> <u>'uncomfortable'</u> wind conditions <u>suitable for pedestrian walking</u>. As <u>this these</u> spaces <u>are is</u> not accessible to building users, no mitigation would be required.
- 10.8810.103 Twenty sevenFifty-five balconies across Building E1 (1200 no.), Building E3 (5 no.) and Building E4 (2 no.), Building C1 (9 no.), Building C2 (10 no.) and —Building C3 (97 no.) and Building C2 (10 no.)—(all detailed Phase 1) would have small spots/localised instances of strong winds exceeding 15m/s for more than the safety threshold of 0.023% of time annually (e.g. 2hrs). All these locations require mitigation to eliminate these safety exceedances.

Mitigation Measures - Scenario 3

- 10.104 CFD modelling results for pedestrian wind comfort for the Development are shown in Figure 10.9 & 10.10 for the annual and windiest (wintersummer) season to address the safety and comfort exceedances specifically within the balconies (detailed Phase 1). Only the mitigation measures applied to the balconies in the previous ES Chapter have been remodelled in this revised report. As such a number of the balconies in detailed Phase 1 still show safety and comfort exceedances in Scenario 3. However, as similar balustrade mitigation measures will be adopted in these locations the wind conditions will be successfully mitigated.
- 10.8910.105 As there are no other 'unsafe' wind conditions within the Development no further

mitigation modelling has been completed at this time.and the safety exceedances due to strong winds for the windiest season in Figures 10.10.

Construction Phase

- <u>10.9010.106</u> No mitigation measures are required during the construction phase (including demolition) of the Development.
- 10.9110.107 As with all major projects there would be appropriate health and safety measures implemented (through a Construction Environment Management Plan (CEMP) secured by condition) to ensure that the construction workers, and any on-site uses that will remain in use throughout the construction, are adequately protected.

Completed Development

- 10.9210.108 Mitigation measures were developed during a number of Mitigation Workshops (21.09.2020 & 02.10.2020) hosted by SRE to enhance the detailed design (Phase 1 of the Development) and the Site wide landscaping strategy. The measures were incorporated into the Development and assessed with further CFD modelling (Scenario 3).
- 10.9310.109 Balustrades have now been included as porous media entities only on the balconies with minor adverse wind conditions. The porosity is based on the detailed drawings for Phase 1 of the Development (refer to Appendix 3.2) and balcony specification details with three levels being used to reflect the different designs (23%, 50% & 73%) and all set to 1.5m in height.
- 10.9410.110 All trees (retained and proposed) have been included as porous media entities within the CFD model with low Leaf Area Index (LAI), in order to capture a worst case wind environment for deciduous trees. (e.g. representing average winter conditions). The heights are as per the landscape plan and the Site Survey data.
- 10.9510.111 Additional mitigation measures were developed during the workshops and incorporated into the Development, and consisted of:
 - An additional deciduous tree (7.5m high) at NE corner of Building P2 (outline Phase 2);
 - Mesh between the columns on the north elevation of the podium level terrace between Buildings C1 & C2 (detailed Phase 1)

- Suitable areas for seating (temporary or fixed) clarified on the podium level terraces of buildings on Block E and between Buildings C1 & C2 (all detailed Phase 1); and
- Included existing (retained) planting off-site to the North of Building P2 (outline Phase
 2).

Residual Effects

Construction Phase

10.9610.112 There are no residual risks associated with the construction phase.

10.9710.113 As the wind conditions during the construction phase (including demolition) adjust from the Baseline Condition (Scenario 1) to the likely wind conditions assessed for the Development once constructed (Scenarios 2 & 3), with the implementation of previously listed measures protecting construction workers and existing users during the phased construction, the wind conditions on-site during the construction phases of the Development would therefore represent a **negligible effect** (not significant).

Operational Phase

Pedestrian Comfort

- 10.9810.114 With the inclusion of the above completed mitigation measures for the Development, the results of the wind microclimate assessment indicate annual wind conditions ranging from suitable for sitting to walking use. during the windiest season.
- 10.9910.115 All Scenario 2 elements with adverse effects have been re-assessed for the Development against the windiest (winter) season (i.e. worst case).annual and summer wind conditions.

Entrances

10.10010.116 The wind conditions south of Building D6 (outline Phase 2) and around Building M1 (outline Phase 4) would have wind conditions suitable for sitting and standing during the windiest season which now reflects the required wind level for this use and is therefore of **negligible effect** (not significant). No further mitigation is required.

Pedestrian Crossings

- 10.117 The off-site pedestrian crossings located to the NW of Building C1 (detailed Phase 1) now has pedestrian standing wind conditions, suitable for the use under annual and summer season.

 This represents a **negligible effect** (not significant) and no further mitigation is required.
- 10.118 The on-site pedestrian crossing located to the south of Building J4 (outline Phase 3) would have annual wind conditions suitable for sitting to pedestrian standing, suitable for the use.

 This represents a **negligible effect** (not significant) and no further mitigation is required.

Ground Level Amenity - Seating

10.10110.119 The ground level amenity space west east of Building C3 (detailed Phase 1), will experience wind conditions suitable for pedestrian sitting during the annual and windiest (winter)summer season, which is suitable for amenity use in the summer season too. Where there remain localised pedestrian standing winds, these areas have not been allocated any permanent seating as part of the landscape design. This represent a negligible effect (not significant) and no further mitigation is required.

Podium Level Amenity - Seating

- 10.120 At the centre and west of the on-site podium level amenity areas on Block E (detailed Phase 1), any proposed fixed seating/amenity have been removed from the landscaping plan and this area would be used for pedestrian access which requires wind conditions suitable for standing during the summer season. No mitigation measures have been modelled on this podium and therefore the remaining area of pedestrian walking will be mitigated by small shrubs and trees. This represents a negligible effect (not-significant) for the podium and no further mitigation is required.
- 10.10210.121 The podium level between C1 & C2 (detailed Phase 1), will experience wind conditions suitable for pedestrian sitting with localised areas of standing located on the access routes where there will be no permanent seating installed. This represents a **negligible effect** (not significant) and no further mitigation is required.

Terraces

10.122 The roof terrace on Building E3 (detailed Phase 1) has not had any mitigation measures applied to the modelling and as such the uncomfortable wind conditions remain. However, the two balconies directly below the terrace that have been modelled with the inclusion of

the balustrades, the uncomfortable wind conditions are mitigated. Further CFD modelling of the terrace can be conditioned as part of the detailed Phase 1 application.

Balconies

- 10.123 The majority of the thirty sixseven—failing balconies on buildings within Blocks B, C & E (detailed Phase 1) have been modelled with the porous media entities reflective of the different enclosure/balustrade designs and the 1.5m height and now have wind conditions in the summer season suitable for sitting acceptable for amenity use and Annual wind safe conditions. This represents a negligible effect (not-significant) and no further mitigation is required.
- 10.10310.124 Not all of the balconies located on Buildings E2 and E3 have been modelled with balustrades the porous media. However, the two balconies that have been (SE corner of Building E3) show that with the inclusion of the balustrades, all uncomfortable and unsafe wind conditions are mitigated. Further CFD modelling of the additional balconies can be conditioned as part of the detailed Phase 1 application.

Roads

10.10410.125 Road locations around the Site would have wind conditions ranging from suitable for sitting to walking use annually and during both the windiest season and the summer season, representing negligible effects (not significant) and no further mitigation is required.

Strong Winds

- 10.10510.126 At ground level, there are now no localised areas of expected strong annual winds exceeding the lower safety threshold level 'unsafe frail' of 15m/s for more than 0.023% throughout the year (ie 2 hours).
- 10.106-Of the five locations where instances of strong winds exceeding 15m/s for more than the safety threshold of 0.023% of time annually (e.g. 2hrs) 'Unsafe Frail' (NW Corners of Buildings C1 & C3 (detailed Phase 1), NW and NE Corners of Building P2 (outline Phase 2), SW Corner of Building K1 (outline Phase 3) and NW Corner of Building M1 (outline Phase 4), the strong winds adjacent to Buildings C1 & C3 have been mitigated by the above measures.
- 10.107-The remaining locations have been reduced to only four localised 'spots': the NW corner of Building P2 (outline Phase 2), NE corner of Building P1 (outline Phase 2), SW Corner of Building K1 (outline Phase 3) and NW Corner of Building M1 (outline Phase 4). These localised

spots show strong winds exceeding 15m/s for more than the safety threshold of 0.023% of time in the windiest season (e.g. 2hrs) and will be resolved through further low-level planting or screening in the locality (refer to Landscape Plan 3.2). This residual risk will be mitigated and the measures will be verified through further CFD modelling at each Reserved Matters Application stage.

- 10.127 All twenty seven Fifty two (of the fifty five) balconies across Building E1 (20 no.), Building E3 (2 no.) and Building E4 (2 no.), Building C1 (9 no.), Building C2 (10 no.) and Building C3 (9 no.) (all detailed Phase 1) Building E1 (10 no.), Building C3 (7 no.) and Building C2 (10 no.) (all detailed Phase 1) no longer have any instances of strong winds exceeding 15m/s for more than the safety threshold of 0.023% of time annually (e.g. 30mins) so the adverse effects have been mitigated.
- 10.10810.128 The remaining 3 balconies (Building E3) have not been modelled with any balustrades

 the porous media. However, the two balconies that have been modelled above these
 balconies (SE corner of Building E3) show that with the inclusion of the balustrades unsafe
 wind conditions are mitigated. Further CFD modelling of the additional balconies can be
 conditioned as part of the detailed Phase 1 application.
- 10.129 The roof terrace on Building E3 (detailed Phase 1) has not had any mitigation measures applied to the modelling and as such the unsafe wind conditions remain. However, the two balconies that have been modelled below this terrace (SE corner of Building E3) show that with the inclusion of the balustrades, uncomfortable and unsafe wind conditions are mitigated. Further CFD modelling of the additional balconies can be conditioned as part of the detailed Phase 1 application.
- <u>10.109</u>10.130 Taking into consideration all of the proposed mitigation measures, the residual effects associated with pedestrian wind comfort on the site will be **negligible**.

Cumulative Effects

- 10.11010.131 There are no cumulative effects directly applicable to the Development, as there are no committed developments within the adjacent area that will have any impact on the wind conditions expected across the Site.
- 10.11110.132 The only proposed new residential scheme is located over 100m away at the southern end of Hampden Road which is located south east of the Site. This committed development is not relevant as this wind direction is the weakest and least frequent wind condition for the area.

Summary

- 10.11210.133 The microclimate assessment quantifies the expected wind microclimate in pedestrian areas at ground level and terrace level for the Site, and also for the detailed Phase 1 individual balconies & terraces, by interpolating the transient CFD results of the Site with hourly weather data in order to predict the frequencies of wind speeds across the course of a whole year.
- 10.11310.134 The modelled wind speed data is benchmarked against the Lawson Comfort Criteria (LCC) to determine the suitability of the Site for different pedestrian activities as well as the Lawson Distress Criteria (LDC) where strong winds are considered and levels of pedestrian safety are assessed 'Safe Conditions'.
- 10.11410.135 The LCC sets five threshold wind speeds appropriate for different pedestrian uses from long term sitting to pedestrian walking.
- 10.11510.136_The results for the windiest (winter) seasonannual period are predominantly presented within the chapter, with inclusion of the windiest (winter) season and summer season to address being the 'worst case' and naturally address the summer season when amenity spaces are more likely to be used frequently. Effects are assessed as being negligible, minor/moderate/major adverse and whether they are temporary or permanent.
- 10.11610.137 The meteorological data for London Heathrow, transposed to site, –has informed the Baseline Conditions, with the prevailing winds being from the SW & W. The existing Site has suitable conditions for sitting to walking use in both the annual windiest (winter) and summer seasons. Localised areas of amenity space around existing Tower Blocks A, B, C & D and building E show wind conditions suitable for business walking use one level windier than suitable for a sitting location as well as four 'uncomfortable' strong winds.
- 10.138 The construction of the Development will result in <u>annual</u> wind conditions suitable for sitting to walking for ground level pedestrian use-<u>during the windiest season</u>. There will be negligible effects during the construction phase. During the operation phase, within the detailed Phase 1 element there are 37-thirty sevenno. balconies that have wind conditions suitable for <u>sitting</u> to localised Business walking standing—one two levels above the amenity use—that provide a <u>minor</u>—moderate adverse effect and are to be mitigated.
- 10.139 Likewise the localised spots of 'unsafe' strong wind at six pedestrian level locations and on fifty five balconies have and will be mitigated through suitable planting, screens and the use of suitable balustrades porous media.

- 10.11710.140 There are five no other locations across the Site with instances of 'unsafe' strong winds exceeding the safety threshold that require mitigation.
- 10.11810.141 Assessment scenario 3 adopted a range of mitigation measures identified and agreed during a number of mitigation workshops, and through changes to the detailed design of the buildings (detailed Phase 1 balconies and terraces) and proposed landscaping plan (retained and new trees) all minor adverse effects have been reduced to negligible in relation to pedestrian wind comfort.
- 10.119-The only residual effects relate to four spots where 'unsafe frail' strong winds are identified (Adjacent to Buildings P1, P2, K1 and M1 (outline element of the Development). These locations are very localised and would be mitigated through the use of additional localised planting and screens to reduce the strong wind level to walking. This is shown in the landscaping plan for the Site (Figure 3.2) and verified through further CFD simulations at each reserved matters application stage.
- 10.12010.142 There are no cumulative effects due to the existing adjacent sites and only committed development is to the SE of the Site which is the least significant wind condition for the area impacting the Development.
- 10.12110.143 Table 10.3 contains a summary of the likely significant effects of the Development.

Table 10.3: Table of Significance – Wind Microclimate

Potential Effect	Nature of Effect	Significance (Major/Moderate/Minor)	Mitigation / Enhancement Measures		Geographical Importance*						Residual Effects
Potential Effect	(Permanent/ Temporary)	(Adverse/Negligible)			UK	Е	R	С	В	L	(Major/Moderate/Minor) (Adverse/Negligible)
Construction											
Wind Impacts during Construction	Temporary	Negligible	N/A							Χ	Negligible
Completed Develo	pment										
Thoroughfares	Permanent	Negligible to Minor Adverse	Retained and new trees and planting within the landscaping along with the overall building layouts throughout the Site.							X	Negligible
Entrance – Building M2	Permanent	Negligible to Minor Adverse	Implementing landscaping within the vicinity of Building M2 such as trees (>5m in height) and shrubs (min 1.5m in height).							X	Negligible
Entrances – other	Permanent	Negligible	N/A							Χ	Negligible
Entrances – off site	Permanent	Negligible	N/A							Χ	Negligible
Pedestrian Crossing	Permanent	Negligible to Minor Adverse	Implementing additional landscaping such as specific new trees (>7.5m in height) and shrubs (min 1.5m in height).							X	Negligible
Ground Level Amenity – Sitting	Permanent	Negligible to Minor Adverse	Implementing additional landscaping such as specific new trees (>7.5m in height) and shrubs (min 1.5m in height).							X	Negligible
Podium Level Amenity – Sitting	Permanent	Negligible to <u>Moderate</u> Adverse	Centre and west area of Podium level amenity on Building plot E to be used for access only. All fixed seating/amenity has been removed from this location in building plot E. Utilise permanent semi-porous (50%) screen between the columns on the north elevation on building plot C. Implementing landscaping elements such as trees (>3m in height), shrubs in planters (min 1.5m in height).							X	Negligible

26902/A5/ES202<u>1</u>0 November 2020MayApril 2021

Terraces (Phase 1)	<u>Permanent</u>	Negligible to Moderate Adverse	1 Terrace on E3 (detailed Phase 1) have balustrades set to min 1.5m in height.	X	<u>Negligible</u>
Balconies (Phase 1)	Permanent	Negligible to <u>Minor</u> <u>Moderate</u> Adverse	37 no. balconies across Phase 1 have balustrades set to min 1.5m in height. Porosity of these balustrades increased (23%, 50% & 73%) and reflect the different designs.	X	Negligible
Strong Winds	Permanent	Significant	Pedestrian Level – suitable planting and screens. Balconies & Terraces – implementing Implementing additional landscaping such as trees (>5m in height) and shrubs (min 1.5m in height) in localised areas. Implementing balustrades set to min 1.5m high (detailed Phase 1).	X	Not Significant
Cumulative Effects					
Wind Impacts during Construction	Temporary	Negligible	N/A	X	Negligible
Operational Phase	Permanent	Negligible	N/A	X	Negligible

* Geographical Level of Importance

I = International; UK = United Kingdom; E = England; R = Regional; C = County; B = Borough; L = Local

REFERENCES

¹ MHCLG (February 2019) National Planning Policy Framework

[&]quot; MHCLG (2014) National Planning Practice Guidance.

iii Met Office (January 2019) UKCP18 Science Overview Executive Summary

^{iv} GLA (December 2019) *The London Plan Intend to Publish (clean version) - Spatial Development Strategy for Greater London (2019)*

v GLA (April 2014) Sustainable Design and Construction Supplementary Planning Guidance (2014)

vi Royal Borough of Kingston upon Thames (April 2012) Core Strategy Local Development Framework (2012)

vii English Heritage & Commission for Architecture and the Built Environment (July 2007) Guidance on Tall Buildings

viii Historic England (December 2015) Tall Buildings Historic England Advice Note 4